

VOC Content Test Certificate

Monday, 24th July 2023

Supplier: All Purpose Coatings (2 Jijaws Street, SUMMER PARK, QLD 4074, AUSTRALIA).

Sample Description: EPO 100T Tinted Epoxy

Date Tested: 21 July 2023 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D2369-10: 2015 Standard Test Method for Volatile Content of Coatings: Table 1 – Method E _ Multi Components Waterborne, Induction time of 24 hours in sealed containers before putting in oven.

Test Data:

<p>Specification</p> <p>Green Building Council of Australia</p> <p>Green Star Design & As Built V1.3 13.1.1</p> <p>Green Star Interiors V1.3 12.1.1B</p>	<p>EPO 100T Tinted Epoxy</p>
<p>One and Two Pack Performance Coatings for Floors:</p> <p>140 grams per Litre as VOC content per material</p>	<p>17 grams per Litre as VOC content per material</p>
<p><i>We hereby certify EPO 100T Tinted Epoxy is below the VOC Content limits of chosen category specified by Green Star Design, Green Building Council of Australia</i></p>	



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Dr. Tuan Duong
PhD, BE (Chem. Eng.)
Senior Consultant



Travis Hale
BSc (Biotechnology)
Senior Consultant

Issue date: 24/7/2023

Expiry date: 24/07/2028

P23070081